

تاريخ الطباعة : 2023-06-14  
وقت الطباعة : PM 12:20  
رقم الطلب : PAC23006542



وزارة الداخلية  
الإدارة العامة للدفاع المدني  
إدارة الوقاية

### شهادة عدم ممانعة

نوع الشهادة : اعتماد منتج

### بيانات المنشأة

الإسم التجاري : هيبورث بي . ام . اي قطر  
رقم السجل التجاري : 22901  
رقم قيد المنشأة : 11-6772-00  
البريد الإلكتروني :  
التصنيف : Fire Fighting Systems  
إسم المنتج : Pipes and fittings

### تفاصيل الشهادة

تم مراجعة الطلب المقدم واتضح بأنه لا مانع من اعتماد المنتج /المنتجات الموضحة في التقرير الفني المرفق بناء على اعتماده من قبل الهيئته المختبرية الموضحة في التقرير الفني المرفق.

### ملاحظات

1. يجب على الشركة الالتزام والعمل بما جاء في اشتراطات قسم أنظمة السلامة التي تم الاطلاع والموافقة عليها من خلال الموقع.
2. يجب ان يقوم بتركيب هذا المنتج من قبل مهندسين وفنيين معتمدين من الإدارة العامة للدفاع المدني.
3. يجب ان يحمل المنتج العلامة التجارية للهيئته المختبرية المعتمدة والموضحة في التقرير الفني المرفق .

تاريخ الاعتماد : 2023-06-13 تاريخ الإنتهاء : 2025-06-12

الإدارة العامة للدفاع المدني  
مدير إدارة الوقاية  
الإدارة العامة للدفاع المدني



TECHNICAL REPORT

التقرير الفني

PRODUCT	Pipes and fittings	منتج
PRODUCT APPLICATION	Fire Fighting Systems	تصنيف المعدة
APPLICANT / P.O BOX	هيپورث بي . ام . اي قطر-	مقدم الطلب
MANUFACTURER / LOCATION	GEORG FISCHER PIPING SYSTEMS LTD. / SWITZERLAND	الشركة المصنعة / بلد الصنع

الوصف

الموديل

Polyethylene Pipe Fittings, Spigot Fittings for Electrofusion and Butt Fusion, 90 to 315 nominal pipe size. 215psi rated working pressure. The fittings are manufactured of injection molded PE100.	+GF+ ELGEF Plus 45 Elbow
--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------	-----------------------------

3RD PARTY CERTIFICATE / APPROVAL	PR454844	FACTORY MUTUAL GLOBAL APPROVALS LLC (FM)	شهادة المختبرات المساندة (من هيئات معتمدة)
----------------------------------	----------	------------------------------------------	--------------------------------------------

RECOMMENDATIONS	التوصيات
-----------------	----------

FM APPROVAL ID # PR454844  
FM CLASS 1613

Should be installed and anchored according to the pipe manufacturer's instructions and FM Global Property Loss Prevention Data Sheets.  
For underground fire protection service use only.

This product approval shall comply with the Design, Inspection, Installation, Testing and Maintenance requirements of NFPA 13/24 (and/or other related NFPA Codes / Standards), other acceptable International Codes / Standards, Local Regulations and/or Manufacturer's Published Instructions subject to the technical review and approval of the Authority Having Jurisdiction (Qatar Civil Defense).

الإدارة العامة للدفاع المدني

الإدارة العامة للدفاع المدني  
مدير إدارة الوقاية  
الإدارة العامة للدفاع المدني

